MICROBAC®

Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0994

Auburn Enlarged City School District

Mary Cregg
78 Thornton Avenue
Auburn, NY 13021

Project Name: Owasco Elementary School

Project / PO Number: 202502255
Received: 12/26/2025
Reported: 01/20/2026

Analytical Testing Parameters

Client Sample ID:	1-OWA Fountain Between Gym and Kitchen		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-01	**Collection Date:**	12/18/2025 5:16

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1830	DLO

Client Sample ID:	2-OWA Kitchen 3-Bay Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-02	**Collection Date:**	12/18/2025 5:16

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	0.00129	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1835	DLO

Client Sample ID:	3-OWA Staff Lounge Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-03	**Collection Date:**	12/18/2025 5:17

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1837	DLO

Client Sample ID:	4-OWA Classroom A15 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-04	**Collection Date:**	12/18/2025 5:18

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	0.00208	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1839	DLO

CERTIFICATE OF ANALYSIS

J5L0994

Client Sample ID:	5-OWA A Wing Hallway Fountain 1 Near A13		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-05	**Collection Date:**	12/18/2025 5:20

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1841	DLO

Client Sample ID:	6-OWA A Wing Hallway Fountain 2 Near Cafeteria		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-06	**Collection Date:**	12/18/2025 5:20

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1843	DLO

Client Sample ID:	7-OWA Health Office Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-07	**Collection Date:**	12/18/2025 5:21

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00119	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1848	DLO

Client Sample ID:	8-OWA Main Office Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-08	**Collection Date:**	12/18/2025 5:21

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1850	DLO

Client Sample ID:	9-OWA B Wing Hallway Fountain 1 Near B9		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-09	**Collection Date:**	12/18/2025 5:25

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00219	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1852	DLO

MICROBAC®

Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0994

Client Sample ID:	10-OWA Classroom B9 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-10	**Collection Date:**	12/18/2025 5:26

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	0.00154	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1854	DLO

Client Sample ID:	11-OWA Classroom B11 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-11	**Collection Date:**	12/18/2025 5:29

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1855	DLO

Client Sample ID:	12-OWA Classroom B13 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-12	**Collection Date:**	12/18/2025 5:31

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	0.00336	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1859	DLO

Client Sample ID:	13-OWA Classroom B15 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-13	**Collection Date:**	12/18/2025 5:32

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	0.00345	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1901	DLO

Client Sample ID:	14-OWA Classroom B17 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-14	**Collection Date:**	12/18/2025 5:34

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	0.00372	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1903	DLO

Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0994

Client Sample ID:	15-OWA Classroom B25 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-15	**Collection Date:**	12/18/2025 5:37

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1905	DLO

Client Sample ID:	16-OWA Classroom B27 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-16	**Collection Date:**	12/18/2025 5:37

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1910	DLO

Client Sample ID:	17-OWA Classroom B29 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-17	**Collection Date:**	12/18/2025 5:39

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	**0.00898**	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1912	DLO

Client Sample ID:	18-OWA Classroom B24 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-18	**Collection Date:**	12/18/2025 5:39

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1914	DLO

Client Sample ID:	19-OWA Classroom B22 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-19	**Collection Date:**	12/18/2025 5:38

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1916	DLO

CERTIFICATE OF ANALYSIS

J5L0994

Client Sample ID:	20-OWA Classroom B18 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-20	**Collection Date:**	12/18/2025 5:36

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1420	01/15/26 1917	DLO

Client Sample ID:	21-OWA Classroom B16 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-21	**Collection Date:**	12/18/2025 5:35

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	0.00119	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 1927	DLO

Client Sample ID:	22-OWA B Wing Hallway Fountain 2 Near B16		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-22	**Collection Date:**	12/18/2025 5:35

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 1932	DLO

Client Sample ID:	23-OWA Classroom B12 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-23	**Collection Date:**	12/18/2025 5:33

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	0.00338	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 1934	DLO

Client Sample ID:	24-OWA B Wing Hallway Fountain Near B10		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-24	**Collection Date:**	12/18/2025 5:32

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 1936	DLO

CERTIFICATE OF ANALYSIS

J5L0994

Client Sample ID:	25-OWA Classroom B10 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-25	**Collection Date:**	12/18/2025 5:31

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00261	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 1938	DLO

Client Sample ID:	26-OWA Classroom B8 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-26	**Collection Date:**	12/18/2025 5:29

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00201	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 1940	DLO

Client Sample ID:	27-OWA Classroom B6 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-27	**Collection Date:**	12/18/2025 5:28

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00183	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 1945	DLO

Client Sample ID:	28-OWA Classroom B4 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-28	**Collection Date:**	12/18/2025 5:26

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00119	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 1947	DLO

Client Sample ID:	29-OWA Classroom B2 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-29	**Collection Date:**	12/18/2025 5:24

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00180	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 1949	DLO

CERTIFICATE OF ANALYSIS

J5L0994

Client Sample ID:	30-OWA Library Office Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-30	**Collection Date:**	12/18/2025 5:23

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	**0.0123**	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 1951	DLO

Client Sample ID:	31-OWA C Wing Hallway Fountain Near C9		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-31	**Collection Date:**	12/18/2025 5:43

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00307	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 1952	DLO

Client Sample ID:	32-OWA Classroom C9 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-32	**Collection Date:**	12/18/2025 5:44

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00235	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 1956	DLO

Client Sample ID:	33-OWA Classroom C11 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-33	**Collection Date:**	12/18/2025 5:48

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00194	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 1958	DLO

Client Sample ID:	34-OWA Classroom C13 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-34	**Collection Date:**	12/18/2025 5:50

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00116	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 2000	DLO

Client Sample ID:	35-OWA Classroom C15 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-35	**Collection Date:**	12/18/2025 5:52

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 2002	DLO

Client Sample ID:	36-OWA Classroom C17 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-36	**Collection Date:**	12/18/2025 5:56

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	0.00227	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 2007	DLO

Client Sample ID:	37-OWA Classroom C21 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-37	**Collection Date:**	12/18/2025 5:57

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 2009	DLO

Client Sample ID:	38-OWA Classroom C21 Bubbler		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-38	**Collection Date:**	12/18/2025 5:57

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 2011	DLO

Client Sample ID:	39-OWA Classroom C23 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-39	**Collection Date:**	12/18/2025 5:59

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 2013	DLO

Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0994

Client Sample ID:	40-OWA Classroom C23 Bubbler		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-40	**Collection Date:**	12/18/2025 5:59

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1425	01/15/26 2015	DLO

Client Sample ID:	41-OWA Classroom C22 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-41	**Collection Date:**	12/18/2025 6:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1426	01/15/26 2024	DLO

Client Sample ID:	42-OWA Classroom C22 Bubbler		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-42	**Collection Date:**	12/18/2025 6:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1426	01/15/26 2029	DLO

Client Sample ID:	43-OWA Classroom C20 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-43	**Collection Date:**	12/18/2025 5:58

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1426	01/15/26 2031	DLO

Client Sample ID:	44-OWA Classroom C20 Bubbler		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-44	**Collection Date:**	12/18/2025 5:58

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1426	01/15/26 2033	DLO

MICROBAC

Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0994

Client Sample ID:	45-OWA Classroom C14 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-45	**Collection Date:**	12/18/2025 5:55

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	0.00338	0.00500 AL	0.00100	mg/L		01/15/26 1426	01/15/26 2035	DLO

Client Sample ID:	46-OWA Classroom C14 Bubbler		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-46	**Collection Date:**	12/18/2025 5:55

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	**0.0187**	0.00500 AL	0.00100	mg/L		01/15/26 1426	01/15/26 2037	DLO

Client Sample ID:	47-OWA Classroom C12 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-47	**Collection Date:**	12/18/2025 5:49

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	**0.00820**	0.00500 AL	0.00100	mg/L		01/15/26 1426	01/15/26 2042	DLO

Client Sample ID:	48-OWA Classroom C12 Bubbler		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-48	**Collection Date:**	12/18/2025 5:49

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1426	01/15/26 2044	DLO

Client Sample ID:	49-OWA Classroom C10 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-49	**Collection Date:**	12/18/2025 5:47

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS **Method: EPA 200.8, Rv. 5.4 (1994)**	**Result**	**Limit(s)**	**RL**	**Units**	**Note**	**Prepared**	**Analyzed**	**Analyst**
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1426	01/15/26 2046	DLO

Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0994

Client Sample ID:	50-OWA Classroom C8 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-50	**Collection Date:**	12/18/2025 5:46

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1426	01/15/26 2048	DLO

Client Sample ID:	51-OWA Classroom C6 Sink		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-51	**Collection Date:**	12/18/2025 5:43

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00298	0.00500 AL	0.00100	mg/L		01/15/26 1426	01/15/26 2050	DLO

Client Sample ID:	52-OWA Fountain Near Room C14		
Sample Matrix:	Drinking Water	**Collected By:**	Lenny Marr
Lab Sample ID:	J5L0994-52	**Collection Date:**	12/18/2025 5:51

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/15/26 1426	01/15/26 2053	DLO

*Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.*

Definitions

AL:	US EPA Action Level
MCL:	US EPA Maximum Contaminant Level
mg/L:	Milligrams per Liter
RL:	Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville

11549 New York State Department of Health

CERTIFICATE OF ANALYSIS

J5L0994

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. ***The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Reviewed and Approved By:

Shannon Weeks

Shannon Weeks

Operations Manager

Reported: 01/20/2026 10:27

Chain of Custody

MICROBAC®

Customer:	Auburn Enlarged CSD
Contact:	Mary Cregg
Project:	
Sampled By:	Lenny Marr
Sampler Phone #:	315-856-0076
2nd Sampler:	Brian Kuryla
	315-506-3411

School County	Cayuga
School Type	
School Name	Owasco Elementary School
School ID	OWA
Sampling Event Name	
Building address	66 Letchworth Street, Auburn, NY 13021
Building ID	OWA

Lab ID	Sample Code	Sample Type	Fixture Code	Fixture Type	Fixture Type Use	DRAWING #	Fixture Location Description	Fixture Description	Building Floor #	Water Last Used		Sample Collected		Lead
										Date	Time	Date	Time	
1	1-OWA						Fountain between Gym and Kitchen		1	12/17/2025	10:00:00 PM	12/18/2025	5:16:00 AM	X
2	2-OWA						Kitchen 3-bay sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:16:00 AM	X
3	3-OWA						Staff Lounge sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:17:00 AM	X
4	4-OWA						Classroom A15 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:18:00 AM	X
5	5-OWA						A Wing Hallway fountain 1 near A13		1	12/17/2025	10:00:00 PM	12/18/2025	5:20:00 AM	X
6	6-OWA						A Wing Hallway fountain 2 near Cafeteria		1	12/17/2025	10:00:00 PM	12/18/2025	5:20:00 AM	X
7	7-OWA						Health Office sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:21:00 AM	X
8	8-OWA						Main Office sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:21:00 AM	X
9	9-OWA						B Wing Hallway fountain 1 near B9		1	12/17/2025	10:00:00 PM	12/18/2025	5:25:00 AM	X
10	10-OWA						Classroom B9 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:26:00 AM	X
11	11-OWA						Classroom B11 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:29:00 AM	X
12	12-OWA						Classroom B13 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:31:00 AM	X
13	13-OWA						Classroom B15 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:32:00 AM	X
14	14-OWA						Classroom B17 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:34:00 AM	X
15	15-OWA						Classroom B25 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:37:00 AM	X
16	16-OWA						Classroom B27 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:37:00 AM	X
17	17-OWA						Classroom B29 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:39:00 AM	X
18	18-OWA						Classroom B24 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:39:00 AM	X
19	19-OWA						Classroom B22 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:38:00 AM	X
20	20-OWA						Classroom B18 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:36:00 AM	X
21	21-OWA						Classroom B16 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:35:00 AM	X
22	22-OWA						B Wing Hallway fountain 2 near B16		1	12/17/2025	10:00:00 PM	12/18/2025	5:35:00 AM	X
23	23-OWA						Classroom B12 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:33:00 AM	X
24	24-OWA						B Wing Hallway fountain 3 near B10		1	12/17/2025	10:00:00 PM	12/18/2025	5:32:00 AM	X
25	25-OWA						Classroom B10 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:31:00 AM	X
26	26-OWA						Classroom B8 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:29:00 AM	X
27	27-OWA						Classroom B6 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:28:00 AM	X

J5L0994
Auburn Enlarged City School District
PM: Shannon Weeks

28	28-OWA						Classroom B4 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:26:00 AM	X
29	29-OWA						Classroom B2 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:24:00 AM	X
30	30-OWA						Library Office sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:23:00 AM	X
31	31-OWA						C Wing Hallway fountain near C9		1	12/17/2025	10:00:00 PM	12/18/2025	5:43:00 AM	X
32	32-OWA						Classroom C9 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:44:00 AM	X
33	33-OWA						Classroom C11 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:48:00 AM	X
34	34-OWA						Classroom C13 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:50:00 AM	X
35	35-OWA						Classroom C15 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:52:00 AM	X
36	36-OWA						Classroom C17 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:56:00 AM	X
37	37-OWA						Classroom C21 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:57:00 AM	X
38	38-OWA						Classroom C21 bubbler		1	12/17/2025	10:00:00 PM	12/18/2025	5:57:00 AM	X
39	39-OWA						Classroom C23 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:59:00 AM	X
40	40-OWA						Classroom C23 bubbler		1	12/17/2025	10:00:00 PM	12/18/2025	5:59:00 AM	X
41	41-OWA						Classroom C22 sink		1	12/17/2025	10:00:00 PM	12/18/2025	6:00:00 AM	X
42	42-OWA						Classroom C22 bubbler		1	12/17/2025	10:00:00 PM	12/18/2025	6:00:00 AM	X
43	43-OWA						Classroom C20 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:58:00 AM	X
44	44-OWA						Classroom C20 bubbler		1	12/17/2025	10:00:00 PM	12/18/2025	5:58:00 AM	X
45	45-OWA						Classroom C14 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:55:00 AM	X
46	46-OWA						Classroom C14 bubbler		1	12/17/2025	10:00:00 PM	12/18/2025	5:55:00 AM	X
47	47-OWA						Classroom C12 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:49:00 AM	X
48	48-OWA						Classroom C12 bubbler		1	12/17/2025	10:00:00 PM	12/18/2025	5:49:00 AM	X
49	49-OWA						Classroom C10 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:47:00 AM	X
50	50-OWA						Classroom C8 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:46:00 AM	X
51	51-OWA						Classroom C6 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:43:00 AM	X
52	52-OWA						Fountain near Room C14		1	12/17/2025	10:00:00 PM	12/18/2025	5:51:00 AM	X
53														X
54														X
55														X
56														X
57														X

J5L0994
Auburn Enlarged City School District
PM: Shannon Weeks

Sampled By (signature)	Date/Time	Received By (signature)	Date/Time		
Refer to hard copy of COC and below for signature	*12/18/2025*				X
					X
Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time		X

Chain of Custody

Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time

Sampled By (signature)	Date/Time	Received By (signature)	Date/Time
[illegible]	12/18/25	SWeeks	12/20/25 1355
Relinquished By (signature)	**Date/Time**	**Received By (signature)**	**Date/Time**
Relinquished By (signature)	**Date/Time**	**Received By (signature)**	**Date/Time**

18.3°C

2nd Sampler Signature:
[illegible] 12/18/25

HNO3 ADDED TO SAMPLES — J547017 - RLF 12/31/25

x
x
x
x
x
x
x
x
x
x
x
x
x

J5L0994
Auburn Enlarged City School District
PM: Shannon Weeks