



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0991

Auburn Enlarged City School District

Project Name: Auburn Junior High School

Mary Cregg
78 Thornton Avenue
Auburn, NY 13021

Project / PO Number: 202502255
Received: 12/26/2025
Reported: 01/21/2026

Analytical Testing Parameters

Client Sample ID:	1-AJHS Classroom 101 Sink	Collected By:	Brian Kuryla
Sample Matrix:	Drinking Water	Collection Date:	12/19/2025 3:58
Lab Sample ID:	J5L0991-01		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00256	0.00500 AL	0.00100	mg/L		01/16/26 1749	01/16/26 1826	DLO

Client Sample ID:	2-AJHS Classroom 101 Sink	Collected By:	Brian Kuryla
Sample Matrix:	Drinking Water	Collection Date:	12/19/2025 3:58
Lab Sample ID:	J5L0991-02		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00196	0.00500 AL	0.00100	mg/L		01/16/26 1749	01/16/26 1828	DLO

Client Sample ID:	4-AJHS Classroom 102 Sink	Collected By:	Brian Kuryla
Sample Matrix:	Drinking Water	Collection Date:	12/19/2025 4:00
Lab Sample ID:	J5L0991-04		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00274	0.00500 AL	0.00100	mg/L		01/16/26 1749	01/16/26 1830	DLO

Client Sample ID:	5-AJHS Classroom 102 Sink	Collected By:	Brian Kuryla
Sample Matrix:	Drinking Water	Collection Date:	12/19/2025 4:00
Lab Sample ID:	J5L0991-05		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00347	0.00500 AL	0.00100	mg/L		01/16/26 1749	01/16/26 1832	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0991

Client Sample ID: 6-AJHS Classroom 102 Sink	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:00
Lab Sample ID: J5L0991-06	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00671	0.00500 AL	0.00100	mg/L		01/16/26 1749	01/16/26 1834	DLO

Client Sample ID: 7-AJHS Classroom 102 Sink	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:00
Lab Sample ID: J5L0991-07	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00322	0.00500 AL	0.00100	mg/L		01/16/26 1749	01/16/26 1839	DLO

Client Sample ID: 8-AJHS Main Lobby Fountain	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:02
Lab Sample ID: J5L0991-08	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00122	0.00500 AL	0.00100	mg/L		01/16/26 1749	01/16/26 1841	DLO

Client Sample ID: 9-AJHS Health Office Sink	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:03
Lab Sample ID: J5L0991-09	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/16/26 1749	01/16/26 1843	DLO

Client Sample ID: 10-AJHS Health Office Sink	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:03
Lab Sample ID: J5L0991-10	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00100	0.00500 AL	0.00100	mg/L		01/16/26 1749	01/16/26 1845	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0991

Client Sample ID: 11-AJHS Health Office Sink	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:03
Lab Sample ID: J5L0991-11	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/16/26 1749	01/16/26 1850	DLO

Client Sample ID: 12-AJHS Hallway Behind Auditorium Fountain	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:05
Lab Sample ID: J5L0991-12	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00136	0.00500 AL	0.00100	mg/L		01/16/26 1749	01/16/26 1852	DLO

Client Sample ID: 13-AJHS Food Service Line Sink	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:05
Lab Sample ID: J5L0991-13	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/16/26 1749	01/16/26 1854	DLO

Client Sample ID: 13A - AJHS Food Service Line Sink	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:05
Lab Sample ID: J5L0991-14	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/16/26 1749	01/16/26 1856	DLO

Client Sample ID: 13B - AJHS Food Service Line Sink	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:05
Lab Sample ID: J5L0991-15	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00133	0.00500 AL	0.00100	mg/L		01/16/26 1749	01/16/26 1901	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0991

Client Sample ID: 14-AJHS Staff Lounge Off Cafeteria Sink	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:06
Lab Sample ID: J5L0991-16	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00574	0.00500 AL	0.00100	mg/L		01/16/26 1749	01/16/26 1903	DLO

Client Sample ID: 15-AJHS Cafeteria Fountain	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:06
Lab Sample ID: J5L0991-17	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/16/26 1749	01/16/26 1905	DLO

Client Sample ID: 16-AJHS Cafeteria Fountain	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:06
Lab Sample ID: J5L0991-18	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/16/26 1749	01/16/26 1907	DLO

Client Sample ID: 17-AJHS Technology Hallway Fountain	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:08
Lab Sample ID: J5L0991-19	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/16/26 1749	01/16/26 1909	DLO

Client Sample ID: 18-AJHS Adaptive PE/Fitness Center Fountain	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:08
Lab Sample ID: J5L0991-20	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/16/26 1750	01/16/26 1940	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0991

Client Sample ID: 19-AJHS Gymnasium Fountain	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:10
Lab Sample ID: J5L0991-21	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/16/26 1750	01/16/26 1942	DLO

Client Sample ID: 20-AJHS 7th Grade Hallway by Room 113 Fountain	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:11
Lab Sample ID: J5L0991-22	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/16/26 1750	01/16/26 1947	DLO

Client Sample ID: 23-AJHS 8th Grade Wing Fountain	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:17
Lab Sample ID: J5L0991-25	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/16/26 1750	01/16/26 1949	DLO

Client Sample ID: 24-AJHS Training Room Ice Machine	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:14
Lab Sample ID: J5L0991-26	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00102	0.00500 AL	0.00100	mg/L		01/16/26 1750	01/16/26 1951	DLO

Client Sample ID: 25-AJHS Training Room Sink	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:14
Lab Sample ID: J5L0991-27	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/16/26 1750	01/16/26 1953	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0991

Client Sample ID: 26-AJHS Fountain Near Elevator Lift	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:14
Lab Sample ID: J5L0991-28	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/16/26 1750	01/16/26 1958	DLO

Client Sample ID: 27-AJHS Concession Stand Sink	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:21
Lab Sample ID: J5L0991-29	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00168	0.00500 AL	0.00100	mg/L		01/16/26 1750	01/16/26 2000	DLO

Client Sample ID: 28-AJHS Concession Stand Sink	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:21
Lab Sample ID: J5L0991-30	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00343	0.00500 AL	0.00100	mg/L		01/16/26 1750	01/16/26 2002	DLO

Client Sample ID: 29-AJHS Boys Locker Room Under Gym	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:13
Lab Sample ID: J5L0991-31	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/16/26 1750	01/16/26 2004	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0991

Client Sample ID: 30-AJHS Girls Locker Room Under Gym	Collected By: Brian Kuryla
Sample Matrix: Drinking Water	Collection Date: 12/19/2025 4:15
Lab Sample ID: J5L0991-32	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/16/26 1750	01/16/26 2006	DLO

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL:** US EPA Action Level
- MCL:** US EPA Maximum Contaminant Level
- mg/L:** Milligrams per Liter
- RL:** Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.

Reviewed and Approved By:

Renee Fiske
Customer Relationship Coordinator
Reported: 01/21/2026 11:30

Chain of Custody

Customer: Auburn Enlarged CSD
 Contact: Mary Cregg
 Project:



School County: Cayuga
 School Type:
 School Name: Auburn Junior High School
 School ID: AJHS
 Sampling Event Name:
 Building address: 191 Franklin Street, Auburn, NY 13021
 Building ID: AJHS

Sampled By: Brian Kuryla
 Sampler Phone #: 315-506-3411
 2nd Sampler: Lenny Marr
 315-856-0076

EXT. = EXTERIOR / B = BASEMENT LEVEL

Lab ID	Sample Code	Sample Type	Fixture Code	Fixture Type	Fixture Type Use	DRAWING #	Fixture Location Description	Fixture Description	Building Floor #	Water Last Used		Sample Collected		Lead
										Date	Time	Date	Time	
1	1-AJHS						Classroom 101 sink		1	12/18/2025	10:00:00 PM	12/19/2025	3:58:00 AM	X
2	2-AJHS						Classroom 101 sink		1	12/18/2025	10:00:00 PM	12/19/2025	3:58:00 AM	X
3	3-AJHS			FOUNTAIN REMOVED			Counselor's Hallway fountain		1					X
4	4-AJHS						Classroom 102 sink		1	12/18/2025	10:00:00 PM	12/19/2025	4:00:00 AM	X
5	5-AJHS						Classroom 102 sink		1	12/18/2025	10:00:00 PM	12/19/2025	4:00:00 AM	X
6	6-AJHS						Classroom 102 sink		1	12/18/2025	10:00:00 PM	12/19/2025	4:00:00 AM	X
7	7-AJHS						Classroom 102 sink		1	12/18/2025	10:00:00 PM	12/19/2025	4:00:00 AM	X
8	8-AJHS						Main Lobby fountain		1	12/18/2025	10:00:00 PM	12/19/2025	4:02:00 AM	X
9	9-AJHS						Health Office sink		1	12/18/2025	10:00:00 PM	12/19/2025	4:03:00 AM	X
10	10-AJHS						Health Office sink		1	12/18/2025	10:00:00 PM	12/19/2025	4:03:00 AM	X
11	11-AJHS						Health Office sink		1	12/18/2025	10:00:00 PM	12/19/2025	4:03:00 AM	X
12	12-AJHS						Hallway behind Auditorium fountain		1	12/18/2025	10:00:00 PM	12/19/2025	4:05:00 AM	X
13	13-AJHS						Food service line sink		1	12/18/2025	10:00:00 PM	12/19/2025	4:05:00 AM	X
14	13A-AJHS						Food service line sink			12/18/2025	10:00:00 PM	12/19/2025	4:05:00 AM	
15	13B-AJHS						Food service line sink			12/18/2025	10:00:00 PM	12/19/2025	4:05:00 AM	
16	14-AJHS						Staff lounge off Cafeteria sink		1	12/18/2025	10:00:00 PM	12/19/2025	4:06:00 AM	X
17	15-AJHS						Cafeteria fountain		1	12/18/2025	10:00:00 PM	12/19/2025	4:06:00 AM	X
18	16-AJHS						Cafeteria fountain		1	12/18/2025	10:00:00 PM	12/19/2025	4:06:00 AM	X
19	17-AJHS						Technology Hallway fountain		1	12/18/2025	10:00:00 PM	12/19/2025	4:08:00 AM	X
20	18-AJHS						Adaptive PE/Fitness Center fountain		1	12/18/2025	10:00:00 PM	12/19/2025	4:08:00 AM	X
21	19-AJHS						Gymnasium fountain		1	12/18/2025	10:00:00 PM	12/19/2025	4:10:00 AM	X
22	20-AJHS						7th Grade Hallway by Room 113 fountain		1	12/18/2025	10:00:00 PM	12/19/2025	4:11:00 AM	X
23	21-AJHS			FOUNTAIN REMOVED			Hallway near Library fountain		2					X
24	22-AJHS			FOUNTAIN REMOVED			Science Wing fountain		2					X
25	23-AJHS						8th Grade Wing fountain		2	12/18/2025	10:00:00 PM	12/19/2025	4:17:00 AM	X
26	24-AJHS				Ice Machine		Training Room ice machine		B	12/18/2025	10:00:00 PM	12/19/2025	4:14:00 AM	X
27	25-AJHS						Training Room sink		B	12/18/2025	10:00:00 PM	12/19/2025	4:14:00 AM	X
28	26-AJHS						Fountain near elevator lift		B	12/18/2025	10:00:00 PM	12/19/2025	4:14:00 AM	X
29	27-AJHS						Concession Stand sink		EXT.	12/18/2025	10:00:00 PM	12/19/2025	4:21:00 AM	X

Auburn Enlarged City School District
 PM: Shannon Weeks

510991

Chain of Custody

30	28-AJHS					Concession Stand sink	EXT.	12/18/2025	10:00:00 PM	12/19/2025	4:21:00 AM	X
31	29-AJHS					Boys locker room under Gym	B/EXT.	12/18/2025	10:00:00 PM	12/19/2025	4:13:00 AM	X
32	30-AJHS					Girls locker room under Gym	B/EXT.	12/18/2025	10:00:00 PM	12/19/2025	4:15:00 AM	X
												X
												X
												X
												X
												X

38	Sampled By (signature)		Date/Time	Received By (signature)		Date/Time
39	Refer to hard copy of COC and below for signature		12/19/2025			
40	Relinquished By (signature)		Date/Time	Received By (signature)		Date/Time
41						
42	Relinquished By (signature)		Date/Time	Received By (signature)		Date/Time
43						

44	38	Sampled By (signature)	Date/Time	Received By (signature)	Date/Time
45	39	<i>R.R.R.</i>	12/19/25	<i>[Signature]</i>	12/20/25 1355
46	40	Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time
47	41				
48	42	Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time
49	43				

2nd Sampler Signature: *[Signature]* 12/19/25

188°C IR-1

HN03 ADDED TO SAMPLES - J547017 - RLF 12/31/25

Auburn Enlarged City School District
PM: Shannon Weeks

