



Microbac Laboratories, Inc., New York Division
 CERTIFICATE OF ANALYSIS

Revised Report:
 Amended - See Case
 Narrative.

J5L0993

Auburn Enlarged City School District

Project Name: Herman Ave Elementary School

Mary Cregg
 78 Thornton Avenue
 Auburn, NY 13021

Project / PO Number: 202502255
 Received: 12/26/2025
 Reported: 01/29/2026

Case Narrative

Revision 1 - 01/29/2026 - Report updated to include 3 pages of COC - RLF

Analytical Testing Parameters

Client Sample ID:	1-HER Kitchen Sink 1	Collected By:	Tyler Marr
Sample Matrix:	Drinking Water	Collection Date:	12/18/2025 6:09
Lab Sample ID:	J5L0993-01		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00207	0.00500 AL	0.00100	mg/L		01/22/26 1718	01/22/26 2114	DLO

Client Sample ID:	2-HER Kitchen Sink 2	Collected By:	Tyler Marr
Sample Matrix:	Drinking Water	Collection Date:	12/18/2025 6:10
Lab Sample ID:	J5L0993-02		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00215	0.00500 AL	0.00100	mg/L		01/22/26 1718	01/22/26 2116	DLO

Client Sample ID:	3-HER Kitchen Sink 3	Collected By:	Tyler Marr
Sample Matrix:	Drinking Water	Collection Date:	12/18/2025 6:11
Lab Sample ID:	J5L0993-03		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0118	0.00500 AL	0.00100	mg/L		01/22/26 1718	01/22/26 2118	DLO

Client Sample ID:	5-HER Health Office Sink	Collected By:	Tyler Marr
Sample Matrix:	Drinking Water	Collection Date:	12/18/2025 5:25
Lab Sample ID:	J5L0993-05		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1718	01/22/26 2120	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0993

Client Sample ID: 5A-HER Health Office Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:29
Lab Sample ID: J5L0993-06	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1718	01/22/26 2122	DLO

Client Sample ID: 6A-HER Fountain Near Room 112	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:27
Lab Sample ID: J5L0993-08	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1718	01/22/26 2127	DLO

Client Sample ID: 9-HER Room 111 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:21
Lab Sample ID: J5L0993-11	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00368	0.00500 AL	0.00100	mg/L		01/22/26 1718	01/22/26 2129	DLO

Client Sample ID: 10-HER Room 111 Bubbler	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:22
Lab Sample ID: J5L0993-12	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00795	0.00500 AL	0.00100	mg/L		01/22/26 1718	01/22/26 2131	DLO

Client Sample ID: 13-HER Classroom 129 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:14
Lab Sample ID: J5L0993-15	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00197	0.00500 AL	0.00100	mg/L		01/22/26 1718	01/22/26 2133	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0993

Client Sample ID: 14-HER Classroom 129 Bubblers	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:14
Lab Sample ID: J5L0993-16	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00329	0.00500 AL	0.00100	mg/L		01/22/26 1718	01/22/26 2138	DLO

Client Sample ID: 15-HER Classroom 131 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:08
Lab Sample ID: J5L0993-17	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00351	0.00500 AL	0.00100	mg/L		01/22/26 1718	01/22/26 2140	DLO

Client Sample ID: 16-HER Classroom 131 Bubblers	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:09
Lab Sample ID: J5L0993-18	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00762	0.00500 AL	0.00100	mg/L		01/22/26 1718	01/22/26 2142	DLO

Client Sample ID: 19-HER Classroom 123 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:33
Lab Sample ID: J5L0993-21	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00274	0.00500 AL	0.00100	mg/L		01/22/26 1718	01/22/26 2144	DLO

Client Sample ID: 20-HER Classroom 123 Bubblers	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:34
Lab Sample ID: J5L0993-22	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00326	0.00500 AL	0.00100	mg/L		01/22/26 1718	01/22/26 2150	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0993

Client Sample ID: 21-HER Classroom 125 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:38
Lab Sample ID: J5L0993-23	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00187	0.00500 AL	0.00100	mg/L		01/22/26 1718	01/22/26 2151	DLO

Client Sample ID: 22-HER Classroom 125 Bubbler	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:39
Lab Sample ID: J5L0993-24	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00161	0.00500 AL	0.00100	mg/L		01/22/26 1718	01/22/26 2153	DLO

Client Sample ID: 23-HER Classroom 124 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:36
Lab Sample ID: J5L0993-25	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00486	0.00500 AL	0.00100	mg/L		01/22/26 1718	01/22/26 2155	DLO

Client Sample ID: 24-HER Classroom 124 Bubbler	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:37
Lab Sample ID: J5L0993-26	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00561	0.00500 AL	0.00100	mg/L		01/22/26 1718	01/22/26 2157	DLO

Client Sample ID: 25-HER Classroom 189 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:42
Lab Sample ID: J5L0993-27	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00119	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2212	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0993

Client Sample ID: 26-HER Classroom 189 Bubbler	
Sample Matrix: Drinking Water	Collected By: Tyler Marr
Lab Sample ID: J5L0993-28	Collection Date: 12/18/2025 5:43

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2213	DLO

Client Sample ID: 27-HER Classroom 190 Sink	
Sample Matrix: Drinking Water	Collected By: Tyler Marr
Lab Sample ID: J5L0993-29	Collection Date: 12/18/2025 5:44

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00115	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2215	DLO

Client Sample ID: 28-HER Classroom 190 Bubbler	
Sample Matrix: Drinking Water	Collected By: Tyler Marr
Lab Sample ID: J5L0993-30	Collection Date: 12/18/2025 5:44

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2217	DLO

Client Sample ID: 29-HER Classroom 191 Sink	
Sample Matrix: Drinking Water	Collected By: Tyler Marr
Lab Sample ID: J5L0993-31	Collection Date: 12/18/2025 5:49

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00112	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2219	DLO

Client Sample ID: 30-HER Classroom 191 Bubbler	
Sample Matrix: Drinking Water	Collected By: Tyler Marr
Lab Sample ID: J5L0993-32	Collection Date: 12/18/2025 5:50

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00641	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2225	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0993

Client Sample ID: 31-HER Classroom 192 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:46
Lab Sample ID: J5L0993-33	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00161	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2226	DLO

Client Sample ID: 32-HER Classroom 192 Bubblers	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:47
Lab Sample ID: J5L0993-34	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2228	DLO

Client Sample ID: 33-HER Staff Lounge Room 122 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:31
Lab Sample ID: J5L0993-35	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2230	DLO

Client Sample ID: 35-HER Classroom 152B Classroom Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:55
Lab Sample ID: J5L0993-37	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00235	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2236	DLO

Client Sample ID: 36-HER Room 151 Classroom Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 6:07
Lab Sample ID: J5L0993-38	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00234	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2238	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0993

Client Sample ID: 37-HER Classroom 153 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 6:06
Lab Sample ID: J5L0993-39	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00134	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2239	DLO

Client Sample ID: 38-HER Fountain Near Room 154	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 6:04
Lab Sample ID: J5L0993-40	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2241	DLO

Client Sample ID: 39-HER Classroom 156 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:57
Lab Sample ID: J5L0993-41	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00139	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2247	DLO

Client Sample ID: 40-HER Classroom 158 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:58
Lab Sample ID: J5L0993-42	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00181	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2249	DLO

Client Sample ID: 41-HER Classroom 160 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:59
Lab Sample ID: J5L0993-43	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00133	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2250	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0993

Client Sample ID: 42-HER Classroom 162 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 6:01
Lab Sample ID: J5L0993-44	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00133	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2252	DLO

Client Sample ID: 43-HER Classroom 164 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 6:02
Lab Sample ID: J5L0993-45	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2254	DLO

Client Sample ID: 44-HER Classroom 159 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 6:02
Lab Sample ID: J5L0993-46	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00112	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2309	DLO

Client Sample ID: 45-HER Classroom 157 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 6:03
Lab Sample ID: J5L0993-47	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00136	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2311	DLO

Client Sample ID: 46-HER Classroom 202 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:02
Lab Sample ID: J5L0993-48	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2313	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0993

Client Sample ID: 47-HER Classroom 202 Bubbl	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:03
Lab Sample ID: J5L0993-49	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2315	DLO

Client Sample ID: 48-HER Classroom 208 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 4:36
Lab Sample ID: J5L0993-50	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2316	DLO

Client Sample ID: 49-HER Classroom 208 Bubbl	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 4:37
Lab Sample ID: J5L0993-51	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2322	DLO

Client Sample ID: 50-HER Classroom 203 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:00
Lab Sample ID: J5L0993-52	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2324	DLO

Client Sample ID: 51-HER Classroom 203 Bubbl	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:01
Lab Sample ID: J5L0993-53	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2326	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0993

Client Sample ID: 52-HER Classroom 207 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 4:40
Lab Sample ID: J5L0993-54	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00123	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2327	DLO

Client Sample ID: 53-HER Classroom 207 Bubbler	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 4:41
Lab Sample ID: J5L0993-55	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00206	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2333	DLO

Client Sample ID: 54-HER Classroom 204 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 4:57
Lab Sample ID: J5L0993-56	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2335	DLO

Client Sample ID: 55-HER Classroom 204 Bubbler	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 4:58
Lab Sample ID: J5L0993-57	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2337	DLO

Client Sample ID: 56-HER Classroom 205 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 4:54
Lab Sample ID: J5L0993-58	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.00104	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2339	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0993

Client Sample ID: 57-HER Classroom 205 Bubblers	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 4:55
Lab Sample ID: J5L0993-59	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2344	DLO

Client Sample ID: 58-HER Classroom 213 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 4:50
Lab Sample ID: J5L0993-60	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0175	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2346	DLO

Client Sample ID: 59-HER Classroom 213 Bubblers	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 4:51
Lab Sample ID: J5L0993-61	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0151	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2348	DLO

Client Sample ID: 60-HER Classroom 216 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 4:43
Lab Sample ID: J5L0993-62	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00396	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2350	DLO

Client Sample ID: 61-HER Classroom 216 Bubblers	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 4:44
Lab Sample ID: J5L0993-63	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00324	0.00500 AL	0.00100	mg/L		01/22/26 1719	01/22/26 2351	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0993

Client Sample ID: 62-HER Classroom 214 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 4:48
Lab Sample ID: J5L0993-64	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00937	0.00500 AL	0.00100	mg/L		01/22/26 1721	01/23/26 0006	DLO

Client Sample ID: 63-HER Classroom 214 Bubbler	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 4:49
Lab Sample ID: J5L0993-65	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00376	0.00500 AL	0.00100	mg/L		01/22/26 1721	01/23/26 0008	DLO

Client Sample ID: 64-HER Classroom 215 Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 4:46
Lab Sample ID: J5L0993-66	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00810	0.00500 AL	0.00100	mg/L		01/22/26 1721	01/23/26 0010	DLO

Client Sample ID: 65-HER Classroom 215 Bubbler	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 4:47
Lab Sample ID: J5L0993-67	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00492	0.00500 AL	0.00100	mg/L		01/22/26 1721	01/23/26 0012	DLO

Client Sample ID: 66-HER Fountain Near Gym	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:52
Lab Sample ID: J5L0993-68	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1721	01/23/26 0014	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5L0993

Client Sample ID: 67-HER Room 111A (IT) Sink	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 5:26
Lab Sample ID: J5L0993-69	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0284	0.00500 AL	0.00100	mg/L		01/22/26 1721	01/23/26 0019	DLO

Client Sample ID: 68-HER Fountain Near Room 208	Collected By: Tyler Marr
Sample Matrix: Drinking Water	Collection Date: 12/18/2025 4:34
Lab Sample ID: J5L0993-70	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.00100	0.00500 AL	0.00100	mg/L		01/22/26 1721	01/23/26 0021	DLO

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- MCL: US EPA Maximum Contaminant Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.

Reviewed and Approved By:

Renee Fiske
Customer Relationship Coordinator
Reported: 01/29/2026 14:12

Chain of Custody

Customer: Auburn Enlarged CSD
 Contact: Mary Cregg
 Project:



School County: Cayuga
 School Type:
 School Name: Herman Ave. Elementary School
 School ID: HER
 Sampling Event Name:
 Building address: 2 N. Herman Avenue, Auburn, NY 13021
 Building ID: HER

Sampled By: Tyler Marr
 Sampler Phone #: 315-246-2705

Lab ID	Sample Code	Sample Type	Fixture Code	Fixture Type	Fixture Type Use	DRAWING #	Fixture Location Description	Fixture Description	Building Floor #	Water Last Used		Sample Collected		Test
										Date	Time	Date	Time	
1	1-HER						Kitchen sink 1		1	12/17/2025	10:00:00 PM	12/18/2025	6:09:00 AM	X
2	2-HER						Kitchen sink 2		1	12/17/2025	10:00:00 PM	12/18/2025	6:10:00 AM	X
3	3-HER						Kitchen sink 3		1	12/17/2025	10:00:00 PM	12/18/2025	6:11:00 AM	X
4	4-HER			ICE MACHINE REMOVED			Kitchen ice machine		1					X
5	5-HER						Health Office sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:25:00 AM	X
6	5A-HER						Health Office sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:29:00 AM	X
7	6-HER			OUT OF ORDER / NO WATER TO FOUNTAIN			Library Hallway fountain by Room 131		1					X
8	6A-HER						Fountain near Room 112		1	12/17/2025	10:00:00 PM	12/18/2025	5:27:00 AM	X
9	7-HER			CURRENTLY OUT OF SERVICE			Room 107 sink		1					X
10	8-HER			NO BUBBLER ON SINK			Room 107 bubbler		1					X
11	9-HER						Room 111 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:21:00 AM	X
12	10-HER						Room 111 bubbler		1	12/17/2025	10:00:00 PM	12/18/2025	5:22:00 AM	X
13	11-HER			CURRENTLY OUT OF SERVICE			Room 109 sink		1					X
14	12-HER			CURRENTLY OUT OF SERVICE			Room 109 bubbler		1					X
15	13-HER						Classroom 129 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:14:00 AM	X
16	14-HER						Classroom 129 bubbler		1	12/17/2025	10:00:00 PM	12/18/2025	5:14:00 AM	X
17	15-HER						Classroom 131 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:08:00 AM	X
18	16-HER						Classroom 131 bubbler		1	12/17/2025	10:00:00 PM	12/18/2025	5:09:00 AM	X
19	17-HER			ROOMS NO LONGER EXISTS AFTER CAPITAL PROJECT			Classroom 126 sink		1					X
20	18-HER						Classroom 126 bubbler		1					X
21	19-HER						Classroom 123 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:33:00 AM	X
22	20-HER						Classroom 123 bubbler		1	12/17/2025	10:00:00 PM	12/18/2025	5:34:00 AM	X
23	21-HER						Classroom 125 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:38:00 AM	X
24	22-HER						Classroom 125 bubbler		1	12/17/2025	10:00:00 PM	12/18/2025	5:39:00 AM	X
25	23-HER						Classroom 124 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:36:00 AM	X
26	24-HER						Classroom 124 bubbler		1	12/17/2025	10:00:00 PM	12/18/2025	5:37:00 AM	X
27	25-HER						Classroom 189 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:42:00 AM	X
28	26-HER						Classroom 189 bubbler		1	12/17/2025	10:00:00 PM	12/18/2025	5:43:00 AM	X

Auburn Enlarged City School District
 PM: Shannon Weeks




Chain of Custody

29	27-HER					Classroom 190 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:44:00 AM	X
30	28-HER					Classroom 190 bubbler		1	12/17/2025	10:00:00 PM	12/18/2025	5:44:00 AM	X
31	29-HER					Classroom 191 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:49:00 AM	X
32	30-HER					Classroom 191 bubbler		1	12/17/2025	10:00:00 PM	12/18/2025	5:50:00 AM	X
33	31-HER					Classroom 192 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:46:00 AM	X
34	32-HER					Classroom 192 bubbler		1	12/17/2025	10:00:00 PM	12/18/2025	5:47:00 AM	X
35	33-HER					Staff Lounge Room 122 sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:31:00 AM	X
36	34-HER			NO BUBBLER ON SINK		Classroom 122 bubbler		1					X
37	35-HER					Classroom 152B classroom sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:55:00 AM	X
38	36-HER					Room 151 classroom sink		1	12/17/2025	10:00:00 PM	12/18/2025	6:07:00 AM	X
39	37-HER					Classroom 153 classroom sink		1	12/17/2025	10:00:00 PM	12/18/2025	6:06:00 AM	X
40	38-HER					Fountain near Room 154		1	12/17/2025	10:00:00 PM	12/18/2025	6:04:00 AM	X
41	39-HER					Classroom 156 classroom sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:57:00 AM	X
42	40-HER					Classroom 158 classroom sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:58:00 AM	X
43	41-HER					Classroom 160 classroom sink		1	12/17/2025	10:00:00 PM	12/18/2025	5:59:00 AM	X
44	42-HER					Classroom 162 classroom sink		1	12/17/2025	10:00:00 PM	12/18/2025	6:01:00 AM	X
45	43-HER					Classroom 164 classroom sink		1	12/17/2025	10:00:00 PM	12/18/2025	6:02:00 AM	X
46	44-HER					Classroom 159 classroom sink		1	12/17/2025	10:00:00 PM	12/18/2025	6:02:00 AM	X
47	45-HER					Classroom 157 classroom sink		1	12/17/2025	10:00:00 PM	12/18/2025	6:03:00 AM	X
48	46-HER					Classroom 202 sink		2	12/17/2025	10:00:00 PM	12/18/2025	5:02:00 AM	X
49	47-HER					Classroom 202 bubbler		2	12/17/2025	10:00:00 PM	12/18/2025	5:03:00 AM	X
50	48-HER					Classroom 208 sink		2	12/17/2025	10:00:00 PM	12/18/2025	4:36:00 AM	X
51	49-HER					Classroom 208 bubbler		2	12/17/2025	10:00:00 PM	12/18/2025	4:37:00 AM	X
52	50-HER					Classroom 203 sink		2	12/17/2025	10:00:00 PM	12/18/2025	5:00:00 AM	X
53	51-HER					Classroom 203 bubbler		2	12/17/2025	10:00:00 PM	12/18/2025	5:01:00 AM	X
54	52-HER					Classroom 207 sink		2	12/17/2025	10:00:00 PM	12/18/2025	4:40:00 AM	X
55	53-HER					Classroom 207 bubbler		2	12/17/2025	10:00:00 PM	12/18/2025	4:41:00 AM	X
56	54-HER					Classroom 204 sink		2	12/17/2025	10:00:00 PM	12/18/2025	4:57:00 AM	X
57	55-HER					Classroom 204 bubbler		2	12/17/2025	10:00:00 PM	12/18/2025	4:58:00 AM	X
58	56-HER					Classroom 205 sink		2	12/17/2025	10:00:00 PM	12/18/2025	4:54:00 AM	X
59	57-HER					Classroom 205 bubbler		2	12/17/2025	10:00:00 PM	12/18/2025	4:55:00 AM	X
60	58-HER					Classroom 213 sink		2	12/17/2025	10:00:00 PM	12/18/2025	4:50:00 AM	X
61	59-HER					Classroom 213 bubbler		2	12/17/2025	10:00:00 PM	12/18/2025	4:51:00 AM	X
62	60-HER					Classroom 216 sink		2	12/17/2025	10:00:00 PM	12/18/2025	4:43:00 AM	X


 Auburn Enlarged City School District
 PM: Shannon Weeks

Chain of Custody

Item #	Sample ID	Location	Quantity	Collection Date/Time	Release Date/Time	Remarks
63	61-HER	Classroom 216 bubbler	2	12/17/2025 10:00:00 PM	12/18/2025 4:44:00 AM	X
64	62-HER	Classroom 214 sink	2	12/17/2025 10:00:00 PM	12/18/2025 4:48:00 AM	X
65	63-HER	Classroom 214 bubbler	2	12/17/2025 10:00:00 PM	12/18/2025 4:49:00 AM	X
66	64-HER	Classroom 215 sink	2	12/17/2025 10:00:00 PM	12/18/2025 4:46:00 AM	X
67	65-HER	Classroom 215 bubbler	2	12/17/2025 10:00:00 PM	12/18/2025 4:47:00 AM	X
68	66-HER	Fountain near Gym	1	12/17/2025 10:00:00 PM	12/18/2025 5:52:00 AM	X
69	67-HER	Room 111A (IT) sink	1	12/17/2025 10:00:00 PM	12/18/2025 5:26:00 AM	X
70	68-HER	Fountain near Room 20B	2	12/17/2025 10:00:00 PM	12/18/2025 4:34:00 AM	X
71						X
72						X
73						X
74						X



Sampled By (signature)	Date/Time
Refer to hard copy of CDC and below for signature	12/18/2025
Relinquished By (signature)	Date/Time

Received By (signature)	Date/Time
Received By (signature)	Date/Time

Sampled By (signature)	Date/Time
Relinquished By (signature)	Date/Time

Received By (signature)	Date/Time
Received By (signature)	Date/Time

HN03 ADDED TO SAMPLES - J547017 - RUF 18.8°C JR-1
12/31/25